

C.O.C.: D 095282

REPORT No. B19-18342

Report To:

Lanark Pure Spring
 165 Industrial Ave.,
 Carleton Place ON K7C 3V7 Canada

Attention: Lee Martin

Caduceon Environmental Laboratories

2378 Holly Lane
 Ottawa Ontario K1V 7P1
 Tel: 613-526-0123
 Fax: 613-526-1244

DATE RECEIVED: 20-Jun-19

JOB/PROJECT NO.:

DATE REPORTED: 27-Jun-19

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO.

| | | | | |
|-----------------------|---------------|--|--|--|
| Client I.D. | Spring Source | | | |
| Sample I.D. | B19-18342-1 | | | |
| Date Collected | 20-Jun-19 | | | |

| Parameter | Units | R.L. | Reference Method | Date/Site Analyzed | | | | |
|----------------------------|-------|---------|------------------|--------------------|-----------|--|--|--|
| Fluoride | mg/L | 0.1 | SM4110C | 26-Jun-19/O | < 0.1 | | | |
| Nitrate (N) | mg/L | 0.1 | SM4110C | 26-Jun-19/O | 0.1 | | | |
| Chloride | mg/L | 0.5 | SM4110C | 26-Jun-19/O | 0.9 | | | |
| Sulphate | mg/L | 1 | SM4110C | 26-Jun-19/O | 4 | | | |
| Alkalinity(CaCO3) to pH4.5 | mg/L | 5 | SM 2320B | 24-Jun-19/O | 130 | | | |
| Bicarbonate(as CaCO3) | mg/L | 5 | SM 2320B | 24-Jun-19/O | 130 | | | |
| Arsenic | mg/L | 0.0001 | EPA 200.8 | 26-Jun-19/O | 0.0002 | | | |
| Calcium | mg/L | 0.02 | SM 3120 | 24-Jun-19/O | 37.6 | | | |
| Copper | mg/L | 0.002 | SM 3120 | 24-Jun-19/O | < 0.002 | | | |
| Iron | mg/L | 0.005 | SM 3120 | 24-Jun-19/O | < 0.005 | | | |
| Lead | mg/L | 0.00002 | EPA 200.8 | 26-Jun-19/O | < 0.00002 | | | |
| Magnesium | mg/L | 0.02 | SM 3120 | 24-Jun-19/O | 11.3 | | | |
| Potassium | mg/L | 0.1 | SM 3120 | 24-Jun-19/O | 0.5 | | | |
| Sodium | mg/L | 0.2 | SM 3120 | 24-Jun-19/O | 1.0 | | | |
| Zinc | mg/L | 0.005 | SM 3120 | 24-Jun-19/O | < 0.005 | | | |



Tahir Yapici Ph.D
 Lab Supervisor

R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an *

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill,B-Barrie

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.